

Reg.no. 2005/087037/23

P O Box 32422

**GLENSTANTIA**

0010

Phone: (012) 349 2929

Fax: (012) 349 1519

Cell: 082 892 4565/083 654 9972

Cabletronics cc

P O Box 3136

Dalview

1544

**Attention: Mr Tobie du Plessis**

2 August 2011

Dear Sir

## **COMPLIANCE: "KABELCON" PH30-60 FIRE RESISTANT CABLE**

We hereby certify that Cabletronics has submitted the abovementioned cable for the evaluation of its fire resistance.

The 1 mm<sup>2</sup> single pair "Kabelcon" PH30-60 was tested for a survival period of 60 minutes as stated in section 4.1 of BS EN 50200:2006 (our reference: FTC11/067b)

The cable complies with the recommendations as set out in section 8.19.2d of SANS 10139:2007.

Yours faithfully



K van Dyk BSc Eng (Chem)  
Fire Technology & Consulting Services  
T/a **FIRELAB**